



CITY OF KINGS MOUNTAIN

DEPARTMENT OF BUILDING CODES AND ZONING ENFORCEMENT CHECKLIST FOR LAKE IMPROVEMENT FINAL INSPECTION PIERS, DOCKS AND QUAYS

The following will be required prior to final inspection of piers and quays:

All piers and docks shall have white reflectors located at least six inches above full pool elevation, on the furthest corner of the extension of the pier into the water, which reflects light parallel to the shoreline in each direction and directly across the Lake. White reflectors shall be placed on each side of the pier at intervals of 15' or less, beginning at its outermost extension into the water, and extending to the 736' contour of the shoreline.

Final approval of the construction of any structure shall require an as-built survey and certification of the registered Engineer, Architect, or Landscape Architect that the structure was built substantially in accordance with the approved plans.

Applicant or contractor must call 704-734-4599 when all of the structure is complete and the above items are in place and submitted, for the final inspection.

EFFECTIVE DATE: JULY 28, 2003

